



SIDE VIEW

END VIEW

TANK: CATEGORY 4. 4" 2400 GALLON 2 COMPARTMENT TANK REINFORCED WITH FIBER AND #3 STEEL 12" O/C BOTH WAYS. 4" WALLS AND 4" BOTTOM. INLET AND OUTLET RESILIENT CONNECTORS PER ASTM-923-98. CONNECTORS MUST BE USED WITH APPROVED CLAMP. CONNECTOR WILL ACCEPT 4" PVC PIPE.

LIDS: 4" LID WITH 1-22" ROUND MANHOLE COVER AT EACH END OF TANK
 8" LID WITH 1-22" ROUND MANHOLE COVER AT EACH END OF TANK
 LID IS REINFORCED WITH GRADE 60 REBAR.

TANK & LIDS: 4000 PSI CONCRETE AT 28 DAYS

IMPRINTED ON INLET END OF TANK:

LEGEND: FSI 2400 STATE APPROVAL NUMBER: 01-011-BM7-C4

WEIGHTS: TANK ONLY 14,500
 TANK & 3" LID 18,342
 TANK & 8" LID 22,185

THIS TANK HOUSES THE 1.5 BIOMICROBICS FAST UNIT.

THIS TANK IS H-10 RATED WHEN USED WITH THE 8" LID IN ACCORDANCE WITH THE FLORIDA DEPARTMENT OF HEALTH MEMO DATED MARCH 30, 2010 HSES 10-002.

THIS SEWAGE TREATMENT RECEPTACLE HAS BEEN DESIGNED, CONSTRUCTED AND STRUCTURALLY TESTED IN ACCORDANCE WITH CHAPTER 64E-6.013, FLORIDA ADMINISTRATIVE CODE, (FAC) DATED APRIL 28, 2010.

DRAWING NOT TO SCALE

HOUSES BIOMICROBICS
 1.5 FAST

FLORIDA SEPTIC, INC

P.O. BOX 545
 HAWTHORNE, FLORIDA 32640
 (800) 940-8265

MODEL:

4" 2400 GALLON TANK

REVISED:
 05/01/2011

APPROVAL DATE:
 SEPTEMBER 13, 2007