



SIDE VIEW

**END VIEW** 

TANK: CATEGORY 4. 4" 2000 GALLON 1 COMPARTMENT TANK REINFORCED WITH #3 STEEL 12" O/C. BOTH WAYS. 4" WALLS AND 4" BOTTOM. INLET AND OUTLET RESILIENT CONNECTORS PER ASTM-923-98. CONNECTORS MUST BE USED WITH APPROVED CLAMP. CONNECTOR WILL ACCEPT 4" PVC PIPE.

LIDS: 4" LID WITH 1-22" ROUND MANHOLE COVER AT EACH END OF TANK 8" LID WITH 1-22" ROUND MANHOLE COVER AT EACH END OF TANK BOTH LIDS ARE REINFORED WITH GRADE 60 REBAR.

TANK & LIDS: 4000 PSI CONCRETE AT 28 DAYS

IMPRINTED ON INLET END OF TANK:

LEGEND: FSI2000

STATE APPROVAL: 01-011-38P-C4

WEIGHTS: TANK ONLY 12,030 TANK W/ 5" LID 15,935 TANK W/ 8" LID 19,831

THIS SEWAGE TREATMENT RECEPTACLE HAS BEEN DESIGNED, CONSTRUCTED AND STRUCTURALLY TESTED IN ACCORDANCE WITH CHAPTER 64E-6.013, FLORIDA ADMINISTRATIVE CODE, (FAC) DATED APRIL 28, 2010.

DRAWING NOT TO SCALE

## FLORIDA SEPTIC, INC.

P.O. BOX 545 HAWTHORNE, FLORIDA 32640 (800) 940-8265 MODEL:

4" 2000 GAL. TANK

REVISED: 05/01/2011

APPROVAL DATE: 07/30/2001