



SIDE VIEW

END VIEW

TANK: CATEGORY 3. 2.5" 1100 GALLON 2 COMPARTMENT TANK REINFORCED WITH FIBRILLATED POLYPROPYLENE FIBER. 2 1/2" WALLS AND 3" BOTTOM. INLET AND OUTLET RESILIENT CONNECTORS PER ASTM-923-98. CONNECTORS MUST BE USED WITH APPROVED CLAMP. CONNECTOR WILL ACCEPT 4" PVC PIPE.

LIDS: 3" LID WITH 1-17" ROUND MANHOLE COVER AT EACH END OF TANK
 8" LID WITH 1-22" ROUND MANHOLE COVER AT EACH END OF TANK
 LID IS REINFORCED WITH GRADE 60 REBAR.

TANK & LIDS: 4000 PSI CONCRETE AT 28 DAYS

IMPRINTED ON INLET END OF TANK:

LEGEND: FSI 1100 STATE APPROVAL NUMBER: 01-011-BM1-C3

WEIGHTS: TANK ONLY 5,960
 TANK & 3" LID 7,800
 TANK & 8" LID 10,600

THIS TANK HOUSES THE 0.5 BIOMICROBICS FAST UNIT.

THIS SEWAGE TREATMENT RECEPTACLE HAS BEEN DESIGNED, CONSTRUCTED AND STRUCTURALLY TESTED IN ACCORDANCE WITH CHAPTER 64E-6.013, FLORIDA ADMINISTRATIVE CODE, (FAC) DATED APRIL 28, 2010.

DRAWING NOT TO SCALE

HOUSES BIOMICROBICS
 0.5 FAST

FLORIDA SEPTIC, INC

P.O. BOX 545
 HAWTHORNE, FLORIDA 32640
 (800) 940-8265

MODEL:

2.5" 1100 GALLON TANK

REVISED:
 05/01/2011

APPROVAL DATE:
 OCTOBER 31, 2003